

BUILDING SAFETY CERTIFICATE

Certified that the existing building **Mahaveer State Academy** at Gat No. 1305/1/2/B/1305/1 and 1305/1/2/B/1305/2 Village Kasbe Digraj Tal. Miraj, Dist. Sangli comprised of **Ground floor & First Floor** owned by **Mahaveer State Academy** have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **Assistant Executive Engineer Class-I P.W. Sub-Division, Sangli** on 28/12/2022 in the presence of **Shri. Prashant S. Avadhut, Director** and that the building is fit for occupancy upto classes **I to Xth** with effect from **28/12/2022** for a period of 47 Years in accordance with rule and subject to compliance of the specific conditions as appended.


1. Access to rooftop from the passage of first floor shall be prohibited by installing steel grill
2. Railing should be provided to entrance steps from both sides
3. The lift duct openings shall be covered with grill
4. First floor level parapet openings shall be closed by brick work.
5. Yearly inspection and certification for safety of building shall be done by your institution through the concerned department

Issued on **28/12/2022** at Sangli, by



Out. No. PB/ 1621 /2022
Office of the Assistant Executive Engineer
Class-1, P.W. Sub-Division, Sangli
Dt.

30 DEC 2022


(Amar M. Nalawade)
Assistant Executive Engineer Class-1,
P.W. Sub-Division, Sangli